

Issue Date: October 31, 2017

Letter Report No: G102864076SAT-003B

Recipient's Name: Chuck McCoy  
Company Name: Wall Panel Systems, Inc.  
Address: 1720 Howard Place  
Redlands, CA 92373

Phone: (909) 307-8888  
Email: [cmccoy@wallpanelsystems.com](mailto:cmccoy@wallpanelsystems.com)

Subject: Intertek Letter Report No. G102864076SAT-003B – Testing Results for NFPA 285 Completed Under Project No. G102624217SAT-004

Dear Mr. McCoy,

Intertek has conducted a test for Wall Panel Systems, Inc. containing their WPS ES-500 Concealed Fastener Extrusion system with High Pressure Compact Laminate Panels (See Test Report No. G102864076SAT-001 for Panel Details) on December 8, 2016, for compliance under the following criteria:

*NFPA 285-2012: Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components.*

This test was authorized under Intertek proposal no. 173934R0, dated May 10, 2016.


Wall Panel Systems, Inc. was pursuing a successful Non-Load-Bearing Wall Assembly in accordance to the standard of *NFPA 285-2012: Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components*. After conducting the test for 30 minutes with 10 minute post-test observation period, the system was found to have stayed within the criteria and received a passing result.

This letter report completes the review of the results for the test conducted on November 3, 2016. If you have any questions regarding this letter report, please do not hesitate to contact the undersigned.

Sincerely,


**INTERTEK TESTING SERVICES NA, INC.**

Reported by:



Jon McMillan  
Associate Engineer, Fire Resistance

Reviewed by:



Victor Burgos  
Senior Project Engineer, Fire Resistance



This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only the sample tested. This report by itself does not imply that the material, product or service is or has ever been under an Intertek certification program.

